

Pre-bid Meeting Queries dated March 16, 2017

NOTICE INVITING TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF RING MAIN UNITS (RMUs) FOR CSEZ

NIT No.: WAP/H-3082/CSEZ/O&M/RMU/2017 dated the March 09, 2017

List of Firms:

1. M/s Imperial Engineering Company
2. M/s Goodwill Power Company Pvt Ltd
3. M/s Connect Plus Technologies
4. M/s Electrofine
5. M/s Kerala Switchgear Sales Corporation

Sr. No.	Queries	Reply
1	Changes in Terms of Payment as per NIT (pg. 13)	The Terms of Payment are modified as follows: <ul style="list-style-type: none">• 10% of the total cost against submission of bank guarantee of equivalent amount• 70% on supply of materials at site• 10% on installation, testing and commissioning• 10% on completion of warranty period i.e. twenty four (24) months from the date of commissioning
2	Eligibility Criteria (pg.6)	Grade of Electrical Contractor with competency to execute the 11 kV works.
3	Unit Rates for Termination	The Contractor has to provide unit rates for new 11 kV termination and 11 kV straight-through joints separately.
4	Extension of Last Date for submission	<ul style="list-style-type: none">• The last date for submission of Tender is hereby extended to March 27, 2017 till 11.00 am.• The technical bids shall be opened on the same day at 11.30 am.• No further extension shall be given.
5	Suspension, Termination and Revocation of Agreement (pg. 7)	First Paragraph stands deleted.
6	Please clarify whether separate metering is required for all outgoing feeders as well as incomer. RMU with individual metering facility for outgoing feeders is not a standard item, more time is required to get offer for the same. Hence, time extension for a period of 2 weeks may be granted.	Individual metering facility is not required for Incoming and Outgoing feeders. However, Auxiliary supply is required as per original tender documents.