

Construction of SDF Building in CSEZ - Fire Fighting and Protection System

Minutes of Pre-bid Meeting

Tender No: WAP/ENVV/CSEZ/H-3082/2019/04 dated 31.05.2019

Date & Time: 14.06.2019 at 11:00 AM

Venue: WAPCOS Limited, CSEZ Project Office, Kakkanad

Members Present:

1. Mr. Dharmarajan. P, Intek Security Systems
2. Mr. Akhil K, Allies Fire System
3. Mr. Antony Sobin, Aag India Pvt Ltd
4. Mr. Rahul, Fire Kool

Sl. No	Queries raised by Agencies	Clarification by WAPCOS
1	BOQ: Sl. No 11: Butterfly valve ISI marking and IS 780 is mentioned, but IS standard is 13095. Make of butterfly valve is not mentioned, so shall we consider the same make of Sluice & Non-Return Valve All manufacturers does not have ISI marking	The IS number given in the BoQ is a typographical error. It may be taken as IS 13095, which is the correct one. The make of the item may be taken as the same as of Sluice & Non-Return Valve You may supply any one of the given makes which is having ISI mark.
2	Make of SV/NRV- Zonota mentioned. So please confirm it is Zoloto only	The make given - zonoto is a typographical error. It may be read as Zoloto.
4	Sl.No.17, Hydrant Valve Specification	The item is only Single headed Stainless Steel metal, which is suitable for item no. 20
5	Sl.no.18, Hose reel specification - Thermoplast hose can used?	No, You may supply as per the specification given in the item which is costlier than thermoplast hose
6	Sl.no.34/35, Sprinkler with flexible drop is considered or not?	Yes, it is considered.
7	Sl.No.40, Newage does not manufacture extinguisher, hence Kanex/Safex may include as alternative.	Yes, Kanex make is agreeable

Sl. No	Queries raised by Agencies	Clarification by WAPCOS
8	Sl.no.47, Fire alarm panel specification and S. no.63, two way communication system specification clarity requires	Two way communication system (Pressing type) of same manufacturers of the panel shall be included and integrated with the panel.
9	NOC matters clarity is required (there may be some work in the scope of civil contractor also)	The drawing containing the civil component will be issued for obtaining fire approval. Any modification required for civil work will be done by civil agency.
10	Payment term; request to provide as per CPWD norms (same percentage for all items)	Payment terms is as per NIT only

Sd/-
General Manager (SEZ)